



Bids and Awards Committee

Bid Bulletin No. 1

Supply of Services for the Hosting/Co-Location Facility of SEC

All prospective bidders are hereby informed of the following:


CLARIFICATIONS/AMENDMENTS:

ITEMS FOR CLARIFICATION/AMENDMENT	CLARIFICATIONS/AMENDMENTS				
<p>P. 37 Section III. Bid Data Sheet ITB Clause 1.1</p> <p>The identification number of the Contract is [insert identification number of the contract as provided in the Invitation to Bid].</p>	<p>The identification number of the Contract is 2017-41.</p>				
<p>P. 37 Section III. Bid Data Sheet ITB Clause 5.4</p> <p>Bidder shall include in their bids:</p> <p>1) A photocopy of Approved Contract or Purchase Order/Work;</p>	<p>Bidder shall include in their bids:</p> <p>A photocopy of Approved Contract or Purchase Order/Work; and</p>				
<p>P. 59 Section VI. Schedule of Requirements</p> <table border="1" data-bbox="191 1287 786 1392"> <tr> <th align="center">OUTPUT</th> </tr> <tr> <td>Within 30 days upon receipt of Notice to Proceed</td> </tr> </table>	OUTPUT	Within 30 days upon receipt of Notice to Proceed	<table border="1" data-bbox="818 1287 1414 1392"> <tr> <th align="center">OUTPUT</th> </tr> <tr> <td>Within 45 days upon receipt of Notice to Proceed</td> </tr> </table>	OUTPUT	Within 45 days upon receipt of Notice to Proceed
OUTPUT					
Within 30 days upon receipt of Notice to Proceed					
OUTPUT					
Within 45 days upon receipt of Notice to Proceed					
<p>P. 62 Section VII. Technical Specification Telecommunication Facilities</p> <p>Carrier Agnostic Annex A – Equipment Deployment Checklist</p>	<p>Carrier Agnostic/Telco Neutral Updated attached</p>				


This Bid Bulletin No. 1 shall form an integral part of the Bid Document.

November 10, 2017

Prepared by:


Christian Noel D. Castillo
BAC Secretariat

Reviewed by:


Rodel S. Presco
End-User Representative

Approved by:


Emmanuel Y. Artiza
BAC Chairman

Annex A

EQUIPMENT DEPLOYMENT CHECKLIST

Item No.	Brand & Model	Year Purchased	Equipment Description	Qty	Space Requirement		Power Rating			Heat Dissipation (BTU/hr)
					(LxWxH mm)	RU	AC/DC	Watts	Volts	
1	SunFire V880	2002	Entry-level Server; 4 CPU	2		17	220	2880		9829
2	SunFire V240	2005	Entry-level Server; 4 CPU	2		2	220	400		805
3	SunFire E4900	2005	Midrange Server; 8 CPU	1		17.5	220	4180		14260
4	Oracle Enterprise M4000	2010		1		6	220	2350	2 x 100 – 240V AC	8018
5	Oracle SPARC T4-4	2013		1		5	220	2770		9362
6	Oracle SPARC T5-2	2013		1		5	220	2770		9362
7	C4 Tape Library	2005		1	6.75" x 19"31"		220	900		3070
8	Hitachi Unified Storage 130	2012	Fiber Channel Disk Storage System	1		EIA 19" rack mounted-10U	220	2000		7320
9	HP Desktop PC			1	19"x28" (LxW)		220	120		160.37
10	FortiGate-110c	2010		1	10"x28" (LxW)		220	120		160.37
11	Brocade 200e SAN Switches	2008	FC SAN Switches	2		2	220	120 (60W each)		308 (154 each)
12	3COM Baseline Switch 2226-SGT Plus			1		17.5"x6.5"			100-240V AC	

13	Brocade Switch				1				220	200		160.37
14	Cisco Catalyst Switch				2			17.5	220	86		294
15	Hitachi CR220S	2014	Entry-level Server		2			2	220	800		308
16	Tanberg External Drive LTO5	2014	Tape Drive		1				220	30		
17	FortiGate-110c	2008			1	44 x 432 x 322			220	154		525
17	FortiGate-300c	2015			1	44 x 432 x 322			220	154		525
18	Oracle SPARC T5-2	2016			1			5	220	2770		9362
19	Oracle SPARC T5-2	2016			1			5	220	2770		9362
20	Oracle SPARC T5-2	2016			1			5	220	2770		9362
21	Oracle Server X5-2	2016			1			5	220	2244		9362
22	42U data cabinet				3							